

CITY OF HIGH POINT
PERMIT TO WORK

No 28890

High Point, N. C., 10-30 1990
Permission is hereby granted to Old Dayside Interiors Inc
To Removal One (1) 1,000 gal
#2 Fuel Oil Tank
on the 2001 side of Brentwood St street
between _____ street and _____ street
Estimated Cost \$ _____
Contractor Howell Assoc. Permit Fee \$ 10.00
1238 Montlieu Ave
H-P. Norma L. Lipe
Official of the Building Inspections Department

HIGH POINT FIRE DEPARTMENT
INSPECTIONS/INVESTIGATIONS
434 SOUTH ELM STREET
HIGH POINT, N. C. 27260
883-3160

To: Chief of Fire Prevention Bureau, City of High Point, N. C.

Application is hereby made by the undersigned for a permit to

☒ Remove Underground Tank(s)

☐ Abandon Underground Tank(s) in or on the premises known as:

Old Wayside Interiors, Inc. 2001 Brentwood St., High Point, N.C.
(Business Name and Address)
For: Howell & Associates, 1238 Montlieu Ave, High Point, N.C.

1. Tank Contractor: Exsci Corporation

Contractor's Address: 1108 Old Thomasville Rd, High Point, N.C.

Number, size, and product type of tanks: One (1), 1000 gal

#2 Fuel Oil Tank to be removed

2. Permit shall be obtained for the removal or abandonment of underground tanks in place prior to beginning work.
3. Tank contractor shall be licensed by the local jurisdiction as applicable.
4. Removal and abandonment of underground tanks in place shall comply with all applicable codes and regulations including the Fire Code, Guilford County Health Regulations, N.F.P.A. 327, and A.P.I. Publication 1604.
5. Notify Fire Prevention at 883-3160 and Guilford Environmental at 884-3771 OR 373-3771 prior to removal or abandonment in place.
6. For tank removal or abandonment in place, all liquids shall be removed from the tank(s) and properly disposed of in accordance with applicable laws.
7. Prior to removal or abandonment in place, tanks shall be purged or rendered inert. Purging or inerting shall be conducted in accordance with applicable standards and regulations. For purging, the vapors shall not exceed 20% of the lower flammable limit. For inerting, the oxygen content shall be below 8%. Tank contractor shall have the proper operating meters, combustible gas indicator and/or oxygen meter at each job site.

8. Tanks which have been removed from the ground shall be promptly removed from the premises to a proper facility. Tanks shall be labeled with legible letters at least two (2) inches high similar to the following. Also stencil permit number on tank.

TANKS HAVE CONTAINED LEADED GASOLINE
NOT VAPOR FREE
NOT SUITABLE FOR STORAGE OF FOOD
OR LIQUIDS INTENDED FOR HUMAN OR ANIMAL CONSUMPTION
DATE OF REMOVAL: MONTH/DAY/YEAR

9. Tanks to be transported in accordance with all applicable Local, State, and Federal regulations. Tanks opening to be plugged or capped with one plug having a 1/8 inch vent hole to prevent the tanks from being subjected to excessive differential pressure. Tanks to be secured on a truck for transportation to the storage or disposal site with the 1/8 inch vent hole located at the uppermost point on the tank.
10. Tank contractor shall complete and submit the attached Guilford County form upon completion of removal or abandonment of tanks. Information submitted to be accurate and detailed.
11. Fee for permit is based on size of tank -

0 - 1,000 gal.	\$10.00	6,000 - 8,000	\$18.00
1,000 - 3,000 gal.	\$12.00	8,000 - 10,000	\$20.00
3,000 - 6,000 gal.	\$14.00	10,000 +	\$20.00 plus \$1.00 for every 1,000 gal.

Fees are payable through the Office of Building Inspections at City Hall. Approved permit is obtained through Fire Inspections Office, 434 S. Elm Street, High Point, N. C.

I understand and consent to the above stipulated conditions upon which this permit is granted. Failure to obtain permit and comply with regulations may render you liable to the penalties provided by Law.

William H. McRay
Applicant

L. F. Puck
Fire Inspector
M. H. SHAL

Date: 30 October 90

Date: 10-30-90

Phone: Day 883-7505 Night 854-5631

Permit Granted ☒ Denied ☐